


OJ-Air2Master Software upgrade from old versions to 6.xx

Software upgrade from versions older versions than 6.10 must be made in steps.



Software upgrade steps

Old OJ-Air2Master controllers can't be upgraded to the latest software in one step. If e.g. an upgrade is attempted from SW 5.xx to 6.30 the controller will stop working. The controller must be returned to OJ Electronics for service. The software update process has been slightly modified, and there are no issue in the latest versions where up and downgrade within the 6.xx versions is possible.

Installed Software version...	Software upgrade steps...
SW 2.01, 2.04, 2.06, 2.11, 2.14, 2.15, 2.19, 2.34, 2.37, 2.40, 2.41, 2.52, 2.54, 2.56, 2.75, 2.79.	OBS: Upgrade only possible if the OJ-Air2Master is labelled: "SOFTWARE 3.xx ready" 1) Install sw 3.25 2) Install sw 4.22 3) Install sw 5.24 4) Install sw 6.10 5) Install sw 6.xx
SW 3.11, 3.13, 3.21, 3.24, 3.25.	1) Install sw 4.22 2) Install sw 5.24 3) Install sw 6.10 4) Install sw 6.xx
SW 4.01, 4.02, 4.10, 4.13, 4.18, 4.19, 4.21, 4.22.	1) Install sw 5.24 2) Install sw 6.10 3) Install sw 6.xx
SW 5.01, 5.02, 5.03, 5.04, 5.07, 5.09, 5.20, 5.21, 5.22.	1) Install sw 6.10 2) Install sw 6.xx

Contact

If further technical information is required please contact our support dept.: support@oj.dk.